



Zakład Stolarski „Złoty Sęk: Jerzy Popławski
16-020 Czarna Białostocka, ul. Młynowa 53,
NIP 542 010 77 01,
www.zlotysek.com.pl, poczta@zlotysek.com.pl

HEATING PROCEDURE CERTIFICATE FOR SUBFLOOR WITH UNDERFLOORING HEATING

TO BE COMPLETED BY THE INVESTOR. It concerns one room (e.g. living room, kitchen or others....)

Place of instalation:

a) flat.....b) house.....c)other.....

Address:.....

Type of underfloor heating.....

Type of concrete.....

Date of making concrete.....

DAY	SET AT TEMP.	NOTES	DATE	SIGNED
1.	20 ST C			2.
2.	30 ST c			
3.	40 ST C			
4.	50 ST C			
5.	50 ST C			
6.	50 ST C			
7.	50 ST C			
8.	50 ST C			
9.	50 ST C			
10.	50 ST C (or maximum system operating temperature)			
11.	50 ST C			
12.	50 ST C			
13.	50 ST C			
14.	50 ST C			
15.	50 ST C			
16.	40 ST C			
17.	30 ST c			



Zakład Stolarski „Złoty Sęk: Jerzy Popławski
16-020 Czarna Białostocka, ul. Młynowa 53,
NIP 542 010 77 01,
www.zlotysek.com.pl, poczta@zlotysek.com.pl

18.	20 ST C			
19.	Turn off heating			
20.				
21.				
22.				
23.				
24.	20 ST C			
25.	30 ST c			
26.	40 ST C			
27.	50 ST C			
28.	40 ST C			
29.	30 ST c			
30.	20 ST C			

.....
**Date and signature of fitter,
Stamp of company responsible for assembly**

.....
Date and legible signature of investor

Information for the Investor

Zloty Sek bears no responsibility for assembly carried out contrary to Assembly Instructions.
Additional Information concerning the warranty is available on www.zlotysek.com.pl

An illegibly completed form is not valid. Making false statement on the certificate may constitute grounds for terminating the cooperation agreements.
This document is drawn up in three copies: 1 for investor, 1 for a fitter and 1 for the fitter to submit for Zloty Sek.